





“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

 Delhi Jal Board	 D.J.B. Diary No. 270 Date 19/02/2021 Nangloi, Delhi-41	DELHI JAL BOARD ( GOVT. OF N.C.T. DELHI ) QUALITY CONTROL LABORATORY, WATER TREATMENT PLANT NANGLOI , DELHI-110041	 एक कदम स्वच्छता की ओर
--	--	---	--


Water Samples collected from St. Gregorios School (Recognised) Sector-11 Dwarka  
 Vide Challan no.178 Dated: 11.02.2021

S. No.	Particulars	Units	Limit		S1
			Acceptable	Permissible	
<b>PHYSICAL EXAMINATION</b>					
1.	Date of collection	-----	--	--	12.02.2021
2.	Date of Analysis	-----	--	--	13.02.2021
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	0.55
6.	PH value	-----	6.5	8.5	7.6
7.	Electrical Conductivity	µmho	--	--	137
8.	Total dissolved solids	mg/l	500	2000	67
<b>CHEMICAL EXAMINATION</b>					
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	56
11.	Total Hardness	mg/l	200	600	58
12.	Calcium Hardness	mg/l	--	--	26
13.	Magnesium Hardness	mg/l	--	--	32
14.	Calcium as Ca	mg/l	75	200	10.4
15.	Magnesium as Mg	mg/l	30	100	7.68
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as No <sub>3</sub>	mg/l	45	N.R.	0.90
19.	Sulphate	mg/l	200	400	3.0
20.	Chloride	mg/l	250	1000	10
21.	Dissolved Iron	mg/l	0.3	N.R.	0.01
22.	Fluoride	mg/l	1	1.5	NIL
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	NIL
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS: On the basis of above tested parameters, the sample S-1 can be use for drinking purpose

  
 Chemist

**PRINCIPAL CUM MANAGER**  
**ST. GREGORIOS SCHOOL**  
**(RECOGNISED)**  
 Sector-11, Dwarka, New Delhi-110075

  
**ACWA**  
 Asstt. Chief Water Analyst  
 DELHI JAL BOARD  
 Govt. of N.C.T. Delhi  
 Quality Control Laboratory  
 Water Works, Nangloi, Delhi-41





**SOUTH DELHI MUNICIPAL CORPORATION**  
PUBLIC HEALTH DEPARTMENT : NAJAFGARH ZONE  
DHANSA STAND, NAJAFGARH, NEW DELHI 110043

No: DHO/NGZ/2018/ 44

Dated 8-1-19

1. Name of the School... St. Gregorios School  
run by The Gregorian Orthodox Church Society.
2. School Address... Sector 11, Dwarka, New Delhi 110075
3. No. of Shifts : One Timings... 8.00 am to 1.20 pm
1. No. of Students: Boys... 1010 Girls... 864 Total... 1874
2. No. of Staffs: Male... 18 Female... 69 Total... 87

**Details of Accommodations present in the school**

- Floor area/ space in the Classroom sufficient/ insufficient... Sufficient
- Classes are well lighted/ ill lighted... Well lighted
- Classrooms are well ventilated/ ill ventilated... Well ventilated
- Classes are kept / not kept neat and clean... Neat & cleaned
- Classrooms/Building require / do not require white wash etc... Not required
- Drinking water is wholesome / not wholesome... Wholesome
- Latrine arrangement is sanitary /insanitary... Sanitary from health point of view.

**No. of toilets seats for students**

- One latrine-cum-urinal is required for 25 female students, so total is... Sufficient
- One latrine for 40 male students is required so total is... Sufficient
- Separate toilet arrangement for staff yes / no... Yes separate exist for staff.
- The overall facilities good/adequate/inadequate... Adequate from health point of view & valid upto one year from issuance date

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

St. Gregorios School  
Sector - 11, Dwarka

New Delhi - 110075

**PRINCIPAL CUM MANAGER**  
**ST. GREGORIOS SCHOOL**  
**(RECOGNISED)**  
Sector-11, Dwarka, New Delhi-110075

**Dy. Health Officer**  
Najafgarh Zone  
D.H.O.  
Public Health Department  
Najafgarh Zone

*[Signature]*  
APHE

*[Handwritten signature]*



## SOUTH DELHI MUNICIPAL CORPORATION

PUBLIC HEALTH DEPARTMENT : NAJAFGARHZONE

DHANSA STAND, NAJAFGARH, NEW DELHI 110043

No: DHO/NGZ/2021/1295

Dated 9/7/2021

- Name of the School... St. Gregorios School
- School Address... Gregorios Nagar Sec-11, Dwarka New Delhi-110075
- No. of Shifts : One Timings... 8 am - 2 pm
  - No. of Students: Boys 1002 Girls 865 Total 1877
  - No. of Staffs: Male 20 Female 73 Total 93

### Details of Accommodations present in the school

- Floor area/ space in the Classroom sufficient/ insufficient... Sufficient
- Classes are well lighted/ ill lighted... Well lighted
- Classrooms are well ventilated/ ill ventilated... Well ventilated
- Classes are kept / not kept neat and clean... Kept neat and clean
- Classrooms/Building require / do not require white wash etc... Not required
- Drinking water is wholesome / not wholesome... Wholesome
- Latrine arrangement is sanitary /insanitary... Sanitary from health point of view

### No. of toilets seats for students

- One latrine-cum-urinal is required for 25 female students, so total is... Sufficient
- One latrine for 40 male students is required so total is... Sufficient
- Separate toilet arrangement for staff yes / no... Yes, exist separate for staff
- The overall facilities good/adequate/inadequate... Adequate from health point of view and valid upto one year from date of issuance.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

St. Gregorios School  
Gregorios Nagar, Sec-11 Dwarka  
New Delhi - 110075

Amithal  
9/7/21  
Dy. Health Officer  
Najafgarh Zone  
Deputy Health Officer  
S.D.M.C Najafgarh, Zone